



St. Augustine Fire Department
101 Malaga Street, St. Augustine FL 32084
904-825-1098 Fax: 904-825-1093

Special Event Rules

1. All canopies and tents must have a fire rating applied with a certificate.
2. All cooking that does not create grease laden vapors must have a 2A 10BC multi-purpose fire extinguisher and tagged by a state of Florida licensed dealer.
3. All cooking equipment outside of a structure to include licensed vehicles creating grease laden vapors shall have a K-type fire extinguisher and 2A 10BC multi-purpose fire extinguisher and tagged by a state of Florida licensed dealer.
4. All cooking equipment inside a structure and/or licensed vehicle shall have a functioning hood exhaust and extinguishment system tagged by a Florida licensed dealer with a K-type and multi-purpose 2A 10BC fire extinguisher.
5. All LPG tanks shall be secured during storage and use.
6. Gas cans shall not be stored next to generators.
7. Generators shall not be re-filled during the operation of the generator.
8. All exits shall be accessible during working hours and not be blocked.
9. The use of crowd managers shall be on site during working hours and shall be identified by use of a shirt or sign. One manager per each 250 people.
10. Access roads shall be a minimum of 20 feet wide for fire vehicle ingress and egress.

All questions shall be addresses by contacting Captain Robert J Growick, Fire Marshal
904 825-1098.