


- NOTES:**
1. ALL WELDS TO BE PERFORMED BY A CERTIFIED STRUCTURAL WELDER.
  2. ALL SUPPORT BRACKET MEMBERS SHALL BE 316 STAINLESS STEEL
  3. ALL NUTS, BOLTS, AND WASHERS SHALL BE 316 STAINLESS STEEL.
  4. GAUGE LINE BOLTS & INSERTS TO MATCH  $\phi$  OF 6" PLATE.
  5. ALL PIPE HANGER DETAILS TO BE USED IN CITY R/W SHALL BE APPROVED THROUGH THE CITY OF ST. AUGUSTINE UTILITIES DEPARTMENT ACTIVITY PRIOR TO USE.

**CROSS-SECTION**

**PROFILE**

PIPE SIZE	4"	6"	8"	10"	12"	16"	20"	24"
X	4.80"	6.90"	9.05"	11.10"	13.20"	17.40"	21.60"	25.80"
Y	8"	9"	10"	12"	13"	15"	17"	19"
Z	3/4"	3/4"	3/4"	1"	1"	1"	1-1/4"	1-1/4"

**PIPE HANGER DETAIL**



REVISION DATE:	FEB 2017
NOT TO SCALE	SS-35&W-21