


NOTES:

- 1) LOCATION OF SAMPLE POINT BIBB SHALL NOT BE WITHIN THE ROADWAY BUT SHALL BE ROUTED TO THE ROADWAY SHOULDERS (NON-TRAFFIC AREAS) OF THE ROAD (WHERE APPLICABLE).
- 2) THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE REMOVAL OF ALL PIPING & FITTINGS (AS NOTED IN THIS DETAIL) AFTER BACTERIOLOGICAL CLEARANCE IS RECEIVED.



**TEMPORARY SAMPLE TAP
FOR STUB OUT**

REVISION
DATE:

FEB 2017

NOT TO
SCALE

W-26