

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+



Figure 1: Overview of All Requested Manholes to Rehabilitate

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+



Figure 2: MHs 23, 24, & 25 Located in Northern St. Augustine Adjacent to the “Winn-Dixie” Shopping Plaza

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+




Figure 3: MHs 95, 96, 97, & 108 Located in the Neighborhood (Greater Fullerwood) Just North of the FSDB



Figure 4: MHs 148, 165, 195, & 393 Located in the Neighborhood (Greater Fullerwood) Just North of the FSDB

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+




Figure 5: MHs 127, 197, 189, & 160 Located in the Neighborhood (Greater Fullerwood) Just North of the FSDB



Figure 6: MHs 224, 214, 221, & 226 Located on FSDB Campus

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+



Figure 7: MHs 309, 415, 295, 304, 303, 301, 310, 313, 395, & 391 Located Just South of FSDB



Figure 8: MH 246 at the Intersection of Magnolia Ave and Williams St

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+



Figure 9: MHs 453, 484, & 501 (Uptown)

CoSA Sanitary Sewer Manhole Rehabilitation Basin 20+

#	Date Insp	Lift Station	Address	MH Number ID	Latitude	Longitude	Comments	Depth (VF)
1	6/11/2024	PS-02	3654 N Ponce De Leon Blvd	SSMH000025	29.92576784	-81.32597234		5.08
2	6/11/2024	PS-02	3726 N Ponce De Leon Blvd	SSMH000023	29.92687119	-81.32668539	Bricks Falling Out of Wall	3.83
3	6/11/2024	PS-02	3676 N Ponce De Leon Blvd	SSMH000024	29.92667474	-81.3265622	Bricks Falling Out of Wall	3.92
4	6/11/2024	PS-03	2700 N Ponce De Leon Blvd	SSMH000148	29.91613841	-81.32430038	Ring/Cover Req Replaced	3.08
5	6/12/2024	PS-05	1300 N Ponce De Leon Blvd	SSMH000453	29.9039593	-81.31970815	Debris On Bench	4.33
6	6/12/2024	PS-05	1103 N Ponce De Leon Blvd	SSMH000484	29.90249352	-81.3208104		6.58
7	6/12/2024	PS-05	1103 N Ponce De Leon Blvd	SSMH000501	29.90182056	-81.32048272		6.67
8	6/4/2024	PS-20	75 Douglas Ave	SSMH000128	29.9166265	-81.32067683		3.67
9	6/4/2024	PS-20	22 Sylvan Dr	SSMH000127	29.91677708	-81.31989425		4.00
10	6/4/2024	PS-20	207 San Marco Ave	SSMH000393	29.91415404	-81.32085202	Invert Repair Needed	3.08
11	6/5/2024	PS-20	207 San Marco Ave	SSMH000221	29.91329703	-81.31653813	Storm Sewer Line Cross Thru	11.92
12	6/5/2024	PS-20	46 Macaris St	SSMH000189	29.9148369	-81.31749733		3.17
13	6/5/2024	PS-20	64 Fullerwood Dr	SSMH000160	29.91569114	-81.31660231		6.08
14	6/5/2024	PS-20	207 San Marco Ave	SSMH000224	29.91322025	-81.31749903		9.67
15	6/4/2024	PS-20	28 Macaris St	SSMH000197	29.91453844	-81.31891929		3.08
16	6/7/2024	PS-20	171 San Marco Ave	SSMH000415	29.90860166	-81.31989814		3.67
17	6/5/2024	PS-20	3 Atlantic Ave	SSMH000108	29.917929	-81.31855114	Missing Mortar Between Bricks	3.58
18	6/5/2024	PS-20	36 Hildreth Dr	SSMH000097	29.91845744	-81.31958483	Missing Mortar Between Bricks	3.17
19	6/10/2024	PS-20	38 E San Carlos Ave	SSMH000391	29.90946871	-81.31647483		8.50
20	6/6/2024	PS-20	24 Magnolia Ave	SSMH000246	29.90763219	-81.31643612		3.17
21	6/10/2024	PS-20	17 May St	SSMH000395	29.90928493	-81.31800109		5.00
22	6/4/2024	PS-20	61 Magnolia Ave	SSMH000310	29.91010372	-81.31652773		7.83
23	6/4/2024	PS-20	73 Magnolia Ave	SSMH000303	29.91106942	-81.31669741		11.83
24	6/4/2024	PS-20	73 Magnolia Ave	SSMH000301	29.91109676	-81.31637666		11.00
25	6/6/2024	PS-20	23 Nelmar Ave	SSMH000304	29.91089836	-81.31753477	Crack In Wall	3.92
26	6/6/2024	PS-20	22 Nelmar Ave	SSMH000295	29.91143687	-81.31757514	Bricks Falling Out Of Chimney	3.67
27	6/5/2024	PS-20	21 Atlantic Ave	SSMH000090	29.91895181	-81.31745951		2.50
28	6/5/2024	PS-20	3 Barbour Pl	SSMH000096	29.91847079	-81.3192003		3.92
29	6/6/2024	PS-20	2 1/2 May St	SSMH000309	29.91010432	-81.31978232	Too Small for Dish 12" Dia	4.00
30	6/5/2024	PS-20	36 Hildreth Dr	SSMH000095	29.91850672	-81.31960677	Bricks Falling Out of Wall	2.83
31	6/3/2024	PS-20	207 San Marco Ave	SSMH000226	29.91317821	-81.3158359		12.08
32	6/4/2024	PS-20	237 San Marco Ave	SSMH000165	29.91552841	-81.32217645		4.00
33	6/4/2024	PS-20	231 San Marco Ave	SSMH000195	29.91465936	-81.3219164		4.67
34	6/5/2024	PS-20	207 San Marco Ave	SSMH000214	29.91363937	-81.31648998		8.17
35	6/4/2024	PS-20	25 May St	SSMH000313	29.9099213	-81.31649454		7.08

Total 35-MHs at 192.75-vf

Note: please include an additional 5-MHs and 40-vf for any outliers that have not been identified, MH-160 is the only pre-cast MH, all MHs are 48" diameter